

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7300-1062:135

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Detection Systems Inc., 130 Perinton Parkway, Fairport NY 14450
Contact: Frank Mioduszewski (585) 223-4060 Fax (585) 421-4263

DESIGN: Models DS9602 and DS 9602LC digital alarm communicator transmitter. Model D9602 and D9602LC are identical except that Model D9602 is comprised of Model D9602LC and Model AE203R enclosure. Units are intended for remote station and central station applications. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12/24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use separately listed fire alarm control units.

05-09-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager